

**Intertek Testing & Certification Limited**

Intertek House, Cleeve Road, Leatherhead, Surrey, KT22 7SB, United Kingdom

Phone: +44 (0)1372 370900 Fax: +44 (0)1372 370999

E-mail: cpd.uk@intertek.com Web: www.intertek.com**EC CERTIFICATE OF CONFORMITY****Certificate Number: 0359-CPD-0318-EN1154:1996/A1:2002/AC:2006****Appendix to EC Certificate of conformity**

Supporting test reports for this certificate of conformity are as follows:

A1. Mechanical Test Report

Report Number	Product Name/Model Numbers						
EEV-130104046GZU-002	MAB150	4	8	4	-	1	3
		3		2			
-* designation from fire test shown in Table A2 becomes "1".							

A2. Fire Test Report

Report Number	Product Name/ Model Numbers	Test Method	Fire resistance (minutes)	
			E - Integrity	I - Insulation
EEV-130104046GZU-002	MAB150	BS EN 1634-1:2008	60	60
Door	Orientation	Door opening into the furnace		
	Type	Single swing Wooden Door		
	Nominal Size	826mm wide by 2028mm high by 55mm thick		
Frame	Nominal Size	900mm wide by 2100mm high		
Hardware	Latch	Mortise Lockset; Model: ANAN S/Z-01		
	Hinges	Stainless steel hinge; Quantity: Three; 4" x 3" x 3mm		
	Door Closer	Model: MAB150 Trade Name: MAB Sample ID: S1305248.001 Installation Instructions for door closer-EN4		



Intertek Testing & Certification Limited

Intertek House, Cleeve Road, Leatherhead, Surrey, KT22 7SB, United Kingdom

Phone: +44 (0)1372 370900 Fax: +44 (0)1372 370999

E-mail: cpd.uk@intertek.com Web: www.intertek.com

EC CERTIFICATE OF CONFORMITY

Certificate Number: 0359-CPD-0318-EN1154:1996/A1:2002/AC:2006

In compliance with the Council Directive 89/106/EEC of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to construction products (the Construction Products Directive or CPD), as later amended, it has been stated that the construction product

Product: **Door closer**

Model Ref: **MAB150**

Product Classification					
4	8	4	1	1	3
3		2			

Intended use: On fire and smoke compartmentation doors

Particular conditions applicable: Single action door closer with adjustable closing and latching speed

Placed on the market by: **ASSA ABLOY Italia S.p.a.**, Via Bovaresa, 13 – 40017 San Giovanni In Persiceto (BO), Italy.

And produced in the factory: **A011**

Is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body No. **0359 Intertek Testing & Certification Ltd** – has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all the provisions concerning the attestation of conformity and the performance described in the Annex ZA of the standard **EN 1154:1996/A1:2002/AC:2006** have been met.

This certificate was first issued on **26th June 2013** and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorised to permit copying or distribution of this certificate and then only in its entirety.

	0359-CPD-0318-EN 1154:1996/A1:2002/AC:2006	
David Bigland . Certification Manager – Building Products	Issued Date	26 JUN 2013
	Revision Date	-
	Review Date	20 JUN 2018